

CITY COUNCIL MEETING
JULY 20, 1988

BID FOR PURCHASE
OF PAD-MOUNTED
TRANSFORMERS

RES. NO. 88-90

CC-12(b)
CC-12(d)
cc-47

The City Council was advised that on June 1, 1988, it had approved specifications for the purchase of five 50 KVA, five 75 KVA and five 100 KVA single-phase, and two 1500 KVA three phase pad-mounted transformers. Bids were opened on June 28, 1988. Listed below is a recap of the bids that were received:

PADMOUNT TRANSFORMER BID EVALUATION EUC-88-0628

5-50 KVA Single Phase, 12,000 Grd. Wye, 240/120 Volt

SUPPLIER	"A" TOTAL PRICE FOB LODI INCL. TAX (\$)	"B" COST OF LOSSES (\$)	"A" + "B" LIFE-CYCLE COST (\$)	Del. (Weeks)
WESCO	\$7,074.18	\$5,226.00	\$12,300.00	13-21
McGraw-Edison (*)				
RTE Corp. (*)				
GESCO (*)				
Square-D Co.		No Bid		
Pauwe?S-Chance		No Bid		

(*) Does not meet specifications

5-75 KVA Single Phase, 12,000 Grd. Wye, 240/120 Volt

SUPPLIER	"A" Total Price FOB Lodi Incl. Tax (\$)	"B" Cost of Losses (\$)	"A" + "B" Life-Cycle cost (\$)	DELIVERY (Weeks)
WESCO	\$8,848.35	\$7,476.00	\$16,324.35	19-21
McGraw-Edison (*)				
RTE Corporation (*)				
GESCO(*)				
Square-D Company		No Bid		
Pauwels-Chance		No Bid		

(*) Does not meet specifications